



ALLIANCE CONSULTING ENGINEERS, INC.

POST OFFICE BOX 8147
COLUMBIA, SC 29202-8147

PHONE: (803) 779-2078 FAX: (803) 779-2079

www.allianceCE.com

To: Potential Bidders and Plan Holders Project No. 22202-0013
Re: Addendum No. 1 Provided Via Email/US Mail
Project: +/- 1,530-LF Phase IIA Industrial Park Lane; +/- 1,425-LF Phase IIB North Park Lane; and +/- 1,526-LF Resurface Existing Phase I Roadways (Industrial Park Lane and East Park Lane) at the +/- 139-Acre Lynches River Industrial Park along Dove Sutton Road (S-682) near the Town of Pageland, Chesterfield County, South Carolina
Date November 2, 2023
Bid Date: November 9, 2023 Page 1 of 14

This Addendum is issued pursuant to the Conditions of the Contract and is hereby made part of the Contract Documents and Technical Specifications for the +/- 1,530-LF Phase IIA Industrial Park Lane; +/- 1,425-LF Phase IIB North Park Lane; and +/- 1,526-LF Resurface Existing Phase I Roadways (Industrial Park Lane and East Park Lane) at the +/- 139-Acre Lynches River Industrial Park along Dove Sutton Road (S-682) near the Town of Pageland, Chesterfield County. The addendum serves to clarify, revise, and supersede information from Contract Documents and Specifications. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form. All attachments, if any, are part of this document.

- 1. Meeting Proceedings Non-Mandatory Pre-Bid Conference:** The Non-Mandatory Pre-Bid Meeting Proceedings for Project 22202-0013 - +/- 1,530-LF Phase IIA Industrial Park Lane; +/- 1,425-LF Phase IIB North Park Lane; and +/- 1,526-LF Resurface Existing Phase I Roadways (Industrial Park Lane and East Park Lane) at the +/- 139-Acre Lynches River Industrial Park along Dove Sutton Road (S-682) near the Town of Pageland, Chesterfield County South Carolina, a copy of which is attached hereto, shall be used by all bidders.
- 2. Section 00 41 00 – Bid Form:** Delete ‘Section 00 41 00 – Bid Form’ in its entirety for the +/- 1,530-LF Phase IIA Industrial Park Lane; +/- 1,425-LF Ph IIB North Park Lane; and +/- 1,526-LF Resurface Existing Phase I Roadways (Industrial Park Lane and East Park Lane) at the +/- 139-Acre Lynches River Industrial Park along Dove Sutton Road (S-682) near the Town of Pageland, Chesterfield County Bid Documents dated May 2021 and replace with the attached ‘Section 00 41 00 –Bid Form’ for the updated Bid Form and, a copy of which is

attached hereto and shall be used by all bidders. The items revised:

- Added date of Addendum #1 acknowledgement on page 2; and
 - Combined the three (3) phases into one (1) complete Bid Form.
- 3. Clarification:** Question - *Are you expecting quality problems with existing soils under subgrade?*
- Existing soils are denoted in the Geotechnical Report in Section 02 30 00. Quality of the soil was not an issue on Phase 1 of the Industrial Park. The site is open for review during the bidding phase. It is encouraged for site visits to determine means and methods for an unclassified soil site.
- 4. Clarification:** Question - *If extended quantity of unsatisfactory soil is found in roadway L.O.D.....is there enough suitable soil on the property to replace the MH/CH soils under subgrade? Will all earth materials needed be available on site?*
- Quality of the soil was not an issue on Phase 1 of the Industrial Park. The site is open for review during the bidding phase. It is encouraged for site visits to determine means and methods for an unclassified soil site.
- 5. Clarification:** Question - *Can you give us the station location of the bore holes?*
- As noted in the meeting proceedings, there were no surveyed coordinate points for the boring locations, but the stations will be relative to low points in the existing grades of the profile sheets C3.0 to C3.4. Approximate Stations 1+50 and 13+00 on Industrial Park Lane and Approximate Sta 2+00 on North Park Lane.
- 6. Clarification:** Question - *I think the soil report states:*
- a. *Selective mining for suitable on-site borrow material.*
 - b. *Expect delays and added costs during cool/wet periods.*
 - c. *Since availability of this project is going to be during the very wettest season, can an allowance be made in time for this adverse situation?*
- The Boring Location Map is included in the Geotechnical Subsurface Exploration Report in Section 02 30 00.
- 7. Clarification:** Question - *The specs state that there will be NO PAY for muck excavation.*
- a. *Will All excavation under subgrade (unsuitable/unstable) be paid as undercut excavation? i. Does the NO PAY situation extend to undercut excavation also?*
- As noted in the meeting proceedings, there were no surveyed coordinate points for the boring locations, but the stations will be relative to low points in the existing grades of the profile sheets C3.0 to C3.4. Approximate Stations 1+50 and 13+00 on Industrial Park Lane and Approximate Sta 2+00 on North Park Lane.
- 8. Clarification:** Question - *Do all areas to be grassed receive 3" topsoil???*
- a. *Should all finish grading be to final contours as shown and 3" topsoil added - OR - do we leave all final contours at -3" to allow for topsoil?*
- The final grade depicted on the project plans are top of soil or top of pavement. For shoulder area, leave 3-inches low to allow for topsoil.

9. **Clarification:** Question – *Is all roadway stone to be primed before placing asphalt?*
- As noted in pre-bid proceeding notes, refer to SCDOT 2007 Standard Specifications for Highway Construction for requirement on timing of placement of stone and pavement (Reference Section 305.4.6 and 401.4.18 of the SCDOT Standard Specifications).
10. **Clarification:** Question – *Can a box section of roadway be used for stone placement?*
- See Specifications for stone placement in Section 32 11 23.
11. **Clarification:** Question – *Will all excess excavation & unsuitable material be disposed of on site?*
- Yes.
12. **Clarification:** Question – *Do you anticipate any additional patching to be necessary on the existing paved roads before final surface course is placed?*
- No. The existing pavement conditions will be evaluated before installation of the resurfacing.
13. **Clarification:** Question - *Will the Temporary Haul Road from Lot #5 to North Park Lane require additional erosion control measures?*
- No.
14. **Clarification:** Question - • *To verify the 600 CY of shoulder material in Phase I construction can you provide the width and depth of material to be placed? Also, what preparatory work will be required on the existing shoulder prior to placing material? And finally, how will the material be measured for payment (i.e., truckload, in-place, or survey cross sections)?*
- The bid form has been combined from three (3) roadway phases into one (1) single phase. Earthwork is a Lump Sum item and has been revised accordingly on the Bid Form.
15. **Clarification:** Question - • *How will the 10,000 CY of material in Earthwork Item (Phase IIB) be measured for payment (i.e., truckload, in-place, or survey cross sections)?*
- Earthwork is a Lump Sum item and has been revised accordingly on the Bid Form.

Attachments:

- Pre-bid Meeting Proceedings – Non-Mandatory Pre-Bid Conference (3 pages)
- Sign-In Sheet (1 page)
- Section 00 41 00- Bid Form (7 page)

-----End of Addendum No. 1-----

**Non-Mandatory
Pre-Bid Meeting Proceedings
+/- 1,530-LF Phase IIA Industrial Park Lane; +/- 1,425-LF Phase IIB
North Park Lane; and +/- 1,526-LF Resurface Existing Phase I
Roadways (Industrial Park Lane and East Park Lane)
+/- 139-Acre Lynches River Industrial Park
Chesterfield County, South Carolina**

Meeting Location: 178 Mill Street
Chesterfield, South Carolina 29709

Date of Meeting: Tuesday October 24, 2023, at 10:00 A.M.

Attendees:	Mr. Tim Eubanks	Chesterfield County
	Ms. Michelle Stanley	Chesterfield County
	Ms. Libby Lear	Chesterfield County
	Ms. Courtney Hicks	Chesterfield County
	Mr. Devin Sikes	Anson Contractors, Inc.
	Mr. Don Vaughn	Anson Contractors, Inc.
	Mr. J. F. Harwood	Anson Contractors, Inc.
	Mr. Greg D. Miller	Anson Contractors, Inc.
	Mr. Jeff Furr	Furr Grading and Paving, Inc.
	Mr. Todd Butler	Furr Grading and Paving, Inc.
	Mr. Hunter Johnson	Hogan Construction Group
	Mr. Steve Whaley, P.E.	Alliance Consulting Engineers, Inc.

Mr. Steve Whaley, P.E. of Alliance Consulting Engineers, Inc. began by thanking everyone for attending. A Sign-In Sheet was distributed, and Mr. Whaley noted that the Pre-Bid Meeting was Non-Mandatory, but that the Sign-In Sheet would be kept as a record to note the attendees. Mr. Whaley introduced the Chesterfield County Representative attending.

Mr. Whaley discussed the scope of the project as denoted in the Advertisement for Bid explaining the Base Bid and the Resurfacing from Phase I. Mr. Whaley explained the overall project, noting the intent of the project was to complete all phases for a complete roadway system into the Lynches River Industrial Park. The Phase I priority is to start the first 580-LF of North Park Lane starting at the connection of Dove Sutton Road to Lot 3 for access of Lot 3 construction of the proposed development of the lot. Completing the roadway to Binder Course and the Stormwater Basin #3 for access of construction of Lot 3 is key first critical path, then moving on to complete the remaining portion of the roadway. Construction of the roadway to the entrance of Lot 3 is essential. Construction of the proposed building on Lot 3 is anticipated to follow the completion of the roadway as was done in Phase I. It was noted there are on-site stockpiles with potentially structural material for use. The locations of the stockpiles were shown on the overhead display of the site.



Non-Mandatory Pre-Bid Meeting Proceedings

+/- 1,530-LF Phase IIA Industrial Park Lane; +/- 1,425-LF Phase IIB North Park Lane; and
+/- 1,526-LF Resurface Existing Phase I Roadways (Industrial Park Lane and East Park Lane)
+/- 139-Acre Lynches River Industrial Park
Chesterfield County, South Carolina
October 24, 2023

Routes for access to the work zone to the stockpile will be discussed in the field during the Preconstruction Meeting.

Mr. Whaley noted that the Bid Opening will take place on November 9, 2023, at 2:00 P.M. at the Chesterfield County Council Room located at 178 Mill Street, Chesterfield, South Carolina. The Bid Opening will be open to the public. Alliance Consulting Engineers, Inc. will be providing a recommendation to Chesterfield County Council for consideration at the December 6, 2023 Council Meeting for approval. Questions are to be submitted to Mr. Steve Whaley via email per the Instructions to Bidders. Questions will be accepted until November 1, 2023, at 5:00 P.M. No questions received via telephone will be accepted. An addendum will be provided to all attending, the contractors on the Plan Holders List, and released to the Plan Rooms/Chesterfield County's website once all questions have been received.

The floor was then opened for questions. The questions and responses are as follows:

Q: *It was noted that there were not bid items for bad soil qualities in the low areas?*

A: **The site is unclassified. The soil conditions are noted in Section 02 30 00 through the Geotechnical Subsurface Exploration Report.**

Q: *There are six (6) borings that are showing poor soil. Can the contractors get a location of the borings for site viewing?*

A: **Reference the Boring Log Map within the Geotechnical Subsurface Exploration Report for location in the field.**

Q: *Would a list of coordinates be provided to locate the borings, or locations marked on the plan for contractors not on the plan holders list?*

A: **Coordinates for the boring locations are not available but a Boring Location Map is available in the Geotechnical Subsurface Exploration Report in Section 02 of the Bid Documents.**

Q: *When will the County release the site for construction?*

A: **The results of the Bid Opening will be provided to Chesterfield County for the December 6, 2023, Council Meeting and will be available to begin within a week after the meeting if Council approves to move forward. Chesterfield County could also extend to after the beginning of the year to accommodate current schedules if needed.**

Q: *Will the stone be required to be primed?*

A: **It was noted that due to the specifications being general to cover South Carolina Department of Transportation (SCDOT) and local requirements, priming will be placed per our general specifications (see Specification**



Non-Mandatory Pre-Bid Meeting Proceedings

+/- 1,530-LF Phase IIA Industrial Park Lane; +/- 1,425-LF Phase IIB North Park Lane; and

+/- 1,526-LF Resurface Existing Phase I Roadways (Industrial Park Lane and East Park Lane)

+/- 139-Acre Lynches River Industrial Park

Chesterfield County, South Carolina

October 24, 2023

Section 32 13 13 – Section 3.02 & 3.05). As well as SCDOT 2007 Standard Specifications for Highway Construction under Section 305.4.6 and 401.4.18 for when primer is required.

Q: From the cross sections, will the shoulders have a 3-inch section of topsoil?

A: Yes, the surface will need to have topsoil to allow germination of grass to stabilize the shoulder. It was noted that Chesterfield County would like to use on-site topsoil within the should slopes. Mr. Whaley noted the core of the roadway that will need to be structural to avoid failure of the slope. The owner is providing a third-party agent to review the fill and they can provide assistance with the onsite topsoil and how to mix the onsite soil for structural use of the topsoil stockpiles within the roadway slopes.

With no further questions, Mr. Whaley thanked everyone for their attendance and adjourned the meeting.



PRE-BID MEETING SIGN-IN SHEET

Project Name: +/- 1,530-LF Ph IIA Industrial Park Lane; +/- 1,425-LF Ph IIB North Park Lane; and +/- 1,526-LF Resurface Existing Phase I Roadways (Industrial Park Lane and East Park Lane) at the +/- 139-Acre Lynches River Industrial Park along Dove Sutton Road (S-682) near the Town of Pageland, Chesterfield County, South Carolina

Project No.: 22202-0013

Location: Town of Chesterfield
178 Mill Street
Chesterfield, South Carolina 29709

Date: Tuesday, October 24, 2023 at 10:00 A.M.

PLEASE PRINT CLEARLY

NAME	COMPANY NAME	ADDRESS	Phone	Email
Tim Eubanks	Chesterfield County		843-623-2535	timeubanks@shc.net
Michelle Stanley	Chesterfield County		843-623-2535	mstanley@chesterfieldcounty.sc.gov
LIBBY LEAR	Chesterfield County Econ. Dev.		843-287-2872	llear@chesterfieldcounty.sc.gov
Christy Hicks	Chesterfield County Econ. Dev.		843-623-6520	chicks@chesterfieldcounty.sc.gov
Steve Whaley	Alliance Consulting Engineers, Inc.	PO Box 8147 Columbia, SC 29201	803-779-2078	swhaley@alliancece.com
Hunter Johnson	Hogan Construction Group	10703 Anderson Rd. Eastley SC 29642	864-272-1527	hjohnson@hoganconstructiongroup.com
Devin Sikes	Anson Contractors Inc	PO Box 796 Wadesboro, NC 28170	704-694-6450	devin@ansoncontractorsinc.com
Greg D. Miller	Anson Contractors Inc	" " " "	704-400-6304	greg@ansoncontractorsinc.com
Jeff Furr	Furr Grading and Paving	5817 US Highway 52 South, Cheraw SC	843-537-2881	office@furrgradingandpavinginc.com
JF Harward	Anson Contractors	PO Box 796 Wadesboro	704-694-6450	jf@ansoncontractorsinc.com
Don Vaughn	" "	" "	" "	avrgroup@windstream.net
Todd Bell	Furr			



SECTION 00 41 00

BID FORM

**±1,530-LF Phase IIA Industrial Park Lane; ±1,425-LF Phase IIB
North Park Lane; and ±1,525-LF Resurface Existing Phase I
Roadways (Industrial Park Lane and East Park Lane)
at the ±139-Acre Lynches River Industrial Park
Along Dove Sutton Road (S-682)
Near the Town of Pageland
Chesterfield County, South Carolina
For
Chesterfield County and Chesterfield Economic Development**

TABLE OF ARTICLES

ARTICLE 1 – BID RECIPIENT	2
ARTICLE 2 – BIDDER’S ACKNOWLEDGEMENTS	2
ARTICLE 3 – BIDDER’S REPRESENTATIONS	2
ARTICLE 4 – FURTHER REPRESENTATIONS	3
ARTICLE 5 – BASIS OF BID.....	4
ARTICLE 6 – TIME OF COMPLETION.....	7
ARTICLE 7 – ATTACHMENTS TO THIS BID.....	7
ARTICLE 8 – DEFINED TERMS.....	7
ARTICLE 9 – BID SUBMITTAL.....	8

ARTICLE 1 - BID RECIPIENT

1.01 This Bid is submitted to: By mail : _____ In Person: _____

**Chesterfield County Finance Department
178 Mill Street – Finance Office
Chesterfield, South Carolina 29709**

1.02 The undersigned Bidder proposes and agrees, if this Bid is accepted, to enter into an Agreement with Owner in the form included in the Bidding Documents to perform all Work as specified or indicated in the Bidding Documents for the prices and within the times indicated in this Bid and in accordance with the other terms and conditions of the Bidding Documents.

ARTICLE 2 - BIDDER'S ACKNOWLEDGEMENTS

2.01 Bidder accepts all of the terms and conditions of the Instructions to Bidders, including without limitation those dealing with the disposition of Bid security. This Bid will remain subject to acceptance for sixty (60) days after the Bid opening, or for such longer period of time that Bidder may agree to in writing upon request of Owner.

ARTICLE 3 - BIDDER'S REPRESENTATIONS

3.01 In submitting this Bid, Bidder represents that:

A. Bidder has examined and carefully studied the Bidding Documents, the other related data identified in the Bidding Documents, and the following Addenda, receipt of which is hereby acknowledged.

<u>Addendum No.</u>	<u>Addendum Date</u>	<u>Initials</u>
<u>1</u>	<u>11/03/2023</u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>

B. Bidder has visited the Site and become familiar with and is satisfied as to the general, local and Site conditions that may affect cost, progress, and performance of the Work.

C. Bidder is familiar with and is satisfied as to all federal, state and local Laws and Regulations that may affect cost, progress and performance of the Work.

D. Bidder has carefully studied all: (1) reports of explorations and tests of subsurface conditions at or contiguous to the Site and all drawings of physical conditions in or relating to existing surface or subsurface structures at or contiguous to the Site (except Underground Facilities), which have been identified in Paragraph 4.02 of General Conditions, and (2) reports and drawings of Hazardous Environmental Conditions that have been identified in Paragraph 4.06 of General Conditions.

- E. Bidder has obtained and carefully studied (or accepts the consequences for not doing so) all additional or supplementary examinations, investigations, explorations, tests, studies and data concerning conditions (surface, subsurface and Underground Facilities) at or contiguous to the Site, which may affect cost, progress, or performance of the Work or which relate to any aspect of the means, methods, techniques, sequences, and procedures of construction to be employed by Bidder, including applying the specific means, methods, techniques, sequences, and procedures of construction expressly required by the Bidding Documents to be employed by Bidder, and safety precautions and programs incident thereto.
- F. Bidder does not consider that any further examinations, investigations, explorations, tests, studies, or data are necessary for the determination of this Bid for performance of the Work at the price(s) bid and within the times and in accordance with the other terms and conditions of the Bidding Documents.
- G. Bidder is aware of the general nature of work to be performed by Owner and others at the Site that relates to the Work as indicated in the Bidding Documents.
- H. Bidder has correlated the information known to Bidder, information and observations obtained from visits to the Site, reports and drawings identified in the Bidding Documents, and all additional examinations, investigations, explorations, tests, studies, and data with the Bidding Documents.
- I. The Bidding Documents are generally sufficient to indicate and convey understanding of all terms and conditions for the performance of the Work for which this Bid is submitted.
- J. Bidder will submit written evidence of its authority to do business in the state where the Project is located not later than the date of its execution of the Agreement.

ARTICLE 4 - FURTHER REPRESENTATIONS

4.01 Bidder further represents that:

- A. This Bid is genuine and not made in the interest of or on behalf of any undisclosed individual or entity and is not submitted in conformity with any agreement or rules of any group, association, organization, or corporation.
- B. Bidder has not directly or indirectly induced or solicited any other Bidder to submit a false or sham Bid.
- C. Bidder has not solicited or induced any individual or entity to refrain from bidding.
- D. Bidder has not sought by collusion to obtain for itself any advantage over any other Bidder or over Owner.

ARTICLE 5 – BASIS OF BID

5.01 Bidder will complete the Work in accordance with the Contract Documents for the following unit price(s):

**Phase I - ± 1,526-LF Resurface Existing Roadways (Industrial Park Lane and East Park Lane);
Phase IIA +/- 1,530-LF Roadway Extension (Industrial Park Lane); and
Phase IIB +/- 1,425-LF Roadway Improvements (North Park Lane)
+/- 139-Acre Lynchess River Industrial Park Chesterfield County, South Carolina**

<u>Item No.</u>	<u>Description</u>	<u>Unit</u>	<u>Estimated Quantity</u>	<u>Unit Price</u>	<u>Bid Price</u>
1	Mobilization/Bonds	LS	1	\$	\$
2	Construction Safety/Traffic Control	LS	1	\$	\$
3	Clearing and Grubbing	AC	10	\$	\$
4	Construction Entrance	EA	2	\$	\$
5	Silt Fence	LF	10,250	\$	\$
6	Silt Logs	EA	70	\$	\$
7	Silt Baffles	LF	335	\$	\$
8	Rip Rap Dams, Outlet Protection, and Baffles	SY	165	\$	\$
9	Inlet Protection	EA	3	\$	\$
10	Erosion Control Matting	SY	17,100	\$	\$
11	Earthwork (On-site Excavation/Backfill/Scarification/Compaction - Unclassified)	LS	1	\$	\$
12	18-Inch RCP	LF	232	\$	\$
13	24-Inch Outlet Reinforced Concrete Piping (RCP)	LF	208	\$	\$
14	30-Inch RCP (Extension of SCDOT Cross Culvert)	LF	24	\$	\$
15	Outlet Structure	EA	2	\$	\$
16	Skimmer	EA	2	\$	\$
17	Yard Inlet/Junction Box	EA	6	\$	\$
18	48-Inch RCP	LF	400	\$	\$
19	48-inch Beveled End Section	EA	1	\$	\$
20	Cast-in Past Headwall (Three (3) crossings)	EA	5	\$	\$
21	20-inch Steel Casing (Future Watermain Extension)	LF	62	\$	\$
22	14-Inch Graded Aggregate Base Course	SY	9,950	\$	\$
23	3.75-Inch Asphalt Intermediate Course (Type C)	SY	9,950	\$	\$
24	2-Inch Asphalt Surface Course (Type B)	SY	18,350	\$	\$
25	5-inch Asphalt Aggregate Base Course (550 LB/SY - AABC - SCDOT Base)	SY	220	\$	\$
26	2.25-inch Intermediate Course (250-LB/SY- SCDOT)	SY	220	\$	\$
27	1.85-inch Asphalt Surface Course - Type C - 200 LB/SY SCDOT Surface)	SY	220	\$	\$
28	Tack Coat /Prime Coat	LS	1	\$	\$
29	Directional Arrows, Stop Bars, and Markings	EA	12	\$	\$
30	White Striping	LF	11,400	\$	\$
31	Yellow Striping - Double Center Line	LF	8,800	\$	\$
32	Speed Limit/Stop Signage	EA	17	\$	\$
33	Grassing	AC	6.5	\$	\$

Total Base Bid: \$ _____

Dollars _____ Cents

(\$ _____)

Amounts are to be shown in both words and figures. In case of discrepancy, the amount shown in words will govern.

The above unit prices shall include all labor, materials, bailing, shoring, removal, overhead, profit, insurance, etc., to complete the finish work as stipulated in the Bid Documents.

Unit Prices have been computed in accordance with Paragraph 11.03.B of the General Conditions.

- A. Bidder acknowledges that estimated quantities are not guaranteed and are solely for the purpose of comparison of Bids, and final payment for all Unit Price Bid items will be based on actual quantities, determined as provided in the Contract Documents.

ARTICLE 6 - TIME OF COMPLETION

6.01 Bidder agrees that the Work: ±1,530-LF Phase IIA Industrial Park Lane; ±1,425-LF Phase IIB North Park Lane; and ±1,525-LF Resurface Existing Phase I Roadways (Industrial Park Lane and East Park Lane) at the ±139-Acre Lynches River Industrial Park Along Dove Sutton Road (S-682) Near the Town of Pageland Chesterfield County, South Carolina is to be completed within two hundred seventy (270) calendar days for the Base Bid scope of work after the Notice to Proceed has been issued.

6.02 Bidder accepts the provisions of the Agreement as to liquidated damages in the event of failure to complete the Work within the Contract dates in the amount of **\$500** per day for each calendar day required to complete the work in the manner and within the dates as stated in Paragraph 6.01 above.

ARTICLE 7 - ATTACHMENTS TO THIS BID

7.01 The following documents are attached to and made a condition of this Bid:

- A. Required Bid security in the form of five percent (5%) of the total bid amount.
B. Power of Attorney.

ARTICLE 8 - DEFINED TERMS

8.01 The terms used in this Bid with initial capital letters have the meanings stated in the Instructions to Bidders and General Conditions.

ARTICLE 9 - BID SUBMITTAL

9.01 This Bid submitted by:

An Individual

Name (typed or printed): _____

By: _____ (SEAL)

(Individual's signature)

Title: _____

Doing business as: _____

A Partnership

Partnership Name: _____ (SEAL)

By: _____

(Signature of general partner -- attach evidence of authority to sign)

Title: _____

Name (typed or printed): _____

A Corporation

Corporation Name: _____ (SEAL)

State of Incorporation: _____

Type (General Business, Professional, Service, Limited Liability): _____

By: _____

(Signature – attach evidence of authority to sign)

Name (typed or printed): _____

Title: _____ (CORPORATE SEAL)

Attest _____

Date of Authorization to do business in [South Carolina] is ____ / ____ / ____.

A Joint Venture

Name of Joint Venture: _____

First Joint Venturer Name: _____ (SEAL)

By: _____

(Signature of first joint venture partner -- attach evidence of authority to sign)

Name (typed or printed): _____

Title: _____

Second Joint Venturer Name: _____ (SEAL)

By: _____

(Signature of second joint venture partner -- attach evidence of authority to sign)

Name (typed or printed): _____

Title: _____

(Each joint venturer must sign. The manner of signing for each individual, partnership, and corporation that is a party to the joint venture should be in the manner indicated above.)

Bidder's Business Address _____

Telephone No.: _____ Fax No.: _____

SUBMITTED on _____, 2023.

State Contractor License No. _____